

# Zbiorcza karta odczytowa

za okres: 08-05-2007 - 15-06-2007

Wykonano dnia: 14-06-2007 10:41:35

Licznik: EAP 103.0008039 - Budynek A, pomiar: pobór				Dane za okres: 15-05-2007 06:24 - 07-06-2007 18:26		
Zużycie ze stanów liczydeł						
	S1	S2	S3	S4	Bezstrefowo	Suma
P+ [kWh]	2279.900	0.000	0.000	0.000	2279.900	2279.900

Licznik: EQABP 303.0001107 - Budynek B, pomiar: pobór				Dane za okres: 14-05-2007 08:45 - 07-06-2007 17:43		
Zużycie ze stanów liczydeł						
	S1	S2	S3	S4	Bezstrefowo	Suma
P+ [kWh]	3340.200	0.000	0.000	0.000	3340.200	3340.200
P- [kWh]	0.000	0.000	0.000	0.000	0.000	0.000
Q+ [kvarh]	2348.800	0.000	0.000	0.000	2348.800	2348.800
Q- [kvarh]	0.000	0.000	0.000	0.000	0.000	0.000
Pb [kWh]	3340.200	0.000	0.000	0.000	3340.200	3340.200
Qb [kvarh]	2348.800	0.000	0.000	0.000	2348.800	2348.800
Q1 [kvarh]	----	----	----	----	----	0.000
Q2 [kvarh]	----	----	----	----	----	0.000
Q3 [kvarh]	----	----	----	----	----	0.000
Q4 [kvarh]	----	----	----	----	----	0.000
S+ [kVAh]	----	----	----	----	4212.800	0.000
S- [kVAh]	----	----	----	----	0.000	0.000

Różnica	
	Różnica
I2	0.934
I2+	----
I2-	----
U2	97.815
U2+	----
U2-	----

Tangens			
	Q+ / P+	Q- / P-	Qb / Pb
TG	0.703	----	0.703

Licznik: sEA 503.0001440 - Budynek D, pomiar: pobór				Dane za okres: 30-05-2007 09:16 - 07-06-2007 18:16		
Zużycie ze stanów liczydeł						
	S1	S2	S3	S4	Bezstrefowo	Suma
P+ [kWh]	10.900	0.000	0.000	0.000	10.900	10.900

Licznik: EAP 103.0008043 - Dawne stoły wzorcownicze, pomiar: pobór				Dane za okres: 15-05-2007 09:09 - 07-06-2007 18:10		
Zużycie ze stanów liczydeł						
	S1	S2	S3	S4	Bezstrefowo	Suma
P+ [kWh]	0.000	0.000	0.000	0.000	0.000	0.000

Licznik: EAP 103.0036017 - Hala produkcyjna + informatyka, pomiar: pobór				Dane za okres: 30-05-2007 08:52 - 07-06-2007 17:51		
Zużycie ze stanów liczydeł						
	S1	S2	S3	S4	Bezstrefowo	Suma
P+ [kWh]	908.700	0.000	0.000	0.000	908.700	908.700

Licznik: LZQM 272047 - Rozliczenie, pomiar: pobór				Dane za okres: 21-05-2007 09:07 - 07-06-2007 18:07		
Zużycie ze stanów liczydeł						
	S1	S2	S3	S4	Bezstrefowo	Suma
P+ [kWh]	6116.000	0.000	0.000	0.000	6116.000	6116.000
P- [kWh]	0.000	0.000	0.000	0.000	0.000	0.000
Q+ [kvarh]	3085.720	0.000	0.000	0.000	3085.720	3085.720
Q- [kvarh]	0.310	0.000	0.000	0.000	0.310	0.310
Pb [kWh]	6116.000	0.000	0.000	0.000	6116.000	6116.000
Qb [kvarh]	3085.410	0.000	0.000	0.000	3085.410	3085.410
Q1 [kvarh]	----	----	----	----	----	0.000
Q2 [kvarh]	----	----	----	----	----	0.000
Q3 [kvarh]	----	----	----	----	----	0.000
Q4 [kvarh]	----	----	----	----	----	0.000
S+ [kVAh]	----	----	----	----	----	0.000
S- [kVAh]	----	----	----	----	----	0.000

Różnica	
	Różnica
I2	----
I2+	----
I2-	----
U2	----
U2+	----
U2-	----

Tangens			
	Q+ / P+	Q- / P-	Qb / Pb
TG	0.505	----	0.504

Licznik: sEA 503.0001164 - Sprężarka produkcja, pomiar: pobór				Dane za okres: 31-05-2007 23:59 - 07-06-2007 18:05		
Zużycie ze stanów liczydeł						
	S1	S2	S3	S4	Bezstrefowo	Suma
P+ [kWh]	291.400	0.000	0.000	0.000	----	291.400

Licznik: sEA 503.0001443 - Wzorcownia, pomiar: pobór				Dane za okres: 15-05-2007 06:00 - 07-06-2007 18:00		
Zużycie ze stanów liczydeł						
	S1	S2	S3	S4	Bezstrefowo	Suma
P+ [kWh]	424.500	0.000	0.000	0.000	424.500	424.500